



**GREATER CHENNAI CORPORATION
PUBLIC HEALTH DEPARTMENT
ZONAL OFFICE -VII (AMBATTUR)**

Z.O.VII/ZHO-VII/S.S.C/046 / 2025

Date :22.05.2025

SANITARY CERTIFICATE

I hereby declare that the building and premises of BIRLA OPEN MINDS INTERNATIONAL SCHOOL, S.F.NO: 498/2, THULASI GARDEN, CHELLIAMMAN KOIL MAIN ROAD, ATHIPET VILLAGE, CHENNAI - 600 058. Have been inspected on 21.05.2025 and certify that the accommodation provided for each of the several classes are sufficient for the maximum number of students, staffs which may accommodate and that the building is properly ventilated and lighted, that it is maintained well, that it is neat and clean that the latrine arrangements are adequate and satisfactory, that the supply of drinking water is wholesome and good and that in all other aspects of sanitary is satisfactory.

This certificate is valid for one year from the date of issue.

❖ Condition Apply

G. N. Nayy
SI
SI-86
22/05/25

SO/19
22/5/25

D. P. Jayachandhini
Zonal Health Officer-VII
Zonal Health Office
Zone.7, (Ambattur)
Greater Chennai Corporation
23/5/2025



**GREATER CHENNAI CORPORATION
PUBLIC HEALTH DEPARTMENT
ZONAL OFFICE -VII (AMBATTUR)**

Z.O.VII/ZHO-VII/S.S.C/129 / 2024



SANITARY CERTIFICATE

I hereby declare that the building and premises of BIRLA OPEN MINDS INTERNATIONAL SCHOOL, S.F.NO:498/2, THULASI GARDEN, CHELLIAMMAN KOIL MAIN ROAD, ATHIPET VILLAGE, CHENNAI - 600058. Have been inspected on 03.05.2024 and certify that the accommodation provided for each of the several classes are sufficient for the maximum number of students, staffs which may accommodate and that the building is properly ventilated and lighted, that it is maintained well, that it is neat and clean that the latrine arrangements are adequate and satisfactory, that the supply of drinking water is wholesome and good and that in all other aspects of sanitary is satisfactory. This certificate is valid for one year from the date of issue.

❖ Condition Apply

R. Bharanidharan
SI-86 02/05/24

[Signature]
SO-19/11

[Signature] / 3/5/2024
Zonal Health Officer-VII

Zonal Health Officer
Zone.7, (Ambattur)
Corporation of Chennai



GREATER CHENNAI CORPORATION
PUBLIC HEALTH DEPARTMENT
ZONAL OFFICE - VII (AMBATTUR)

Z.O.VII/ZHO-VII/S.S.C/038/2023



SANITARY CERTIFICATE

I hereby declare that the building and premises of BIRLA OPEN MINDS INTERNATIONAL SCHOOL, S.F.NO:498/2, THULASI GARDEN, CELLIAMMAN KOIL MAIN ROAD, ATHIPET VILLAGE, CHENNAI-600 058. Have been inspected on **03.05.2023** and certify that the accommodation provided for each of the several classes are sufficient for the maximum number of students strength which may be accommodate and that the building is properly ventilated and lighted, that it is maintained well, that it is neat and clean that the latrine arrangements are adequate and satisfactory, that the supply of drinking water is wholesome and good and that in all other aspects of sanitary is satisfactory.

This certificate is valid for one year from the date of issue.

R. Shanmugam
S.I.- 86 03/05/2023

S.O.- 19 03/05/23

D. Priyachandhini
Zonal Health Officer
Zone.7, (Ambattur)
Corporation of Chennai
3/5/2023



EKDANT ENVIRO SERVICES (P) LIMITED

NABL Accredited & MoEF Recognised Laboratory

An ISO 9001 : 2015 and OHSAS (ISO 45001 : 2018) Certified Company

No. R7/1, AVK Tower, North Main Road, Anna Nagar West Extn. Chennai - 600 101.

Phone : 044 - 2615 3349. Mobile : 94444 11178 / 94449 71649

E-mail : ekdantlab@gmail.com / ekdantfinance19@gmail.com

Web : www.ekdantlab.co.in

DATE: 30.06.2023

Test Report

This is to confirm that, we have tested the water sample at
M/s. Birla Open Minds International School, S.F.No:498/2, Thulasi Garden,
Challiamman Kovil Main Road, Athipet Village, Chennai-600058. The results of
the water samples comply with acceptable limits as per the Indian standards
10500:2012. Hence, the above submitted water can be used for drinking purpose.



Ekdant Enviro Services (P) Limited

B. Pige Indu

Authorized Signatory



EKDANT ENVIRO SERVICES (P) LIMITED

NABL Accredited & MoEF Recognised Laboratory
An ISO 9001 : 2015 and OHSAS (ISO 45001 : 2018) Certified Company

No. R7/1, AVK Tower, North Main Road, Anna Nagar West Extn. Chennai - 600 101.
Phone : 044 - 2615 3349. Mobile : 94444 11178 / 94449 71649
E-mail : ekdantlab@gmail.com / ekdantfinance19@gmail.com
Web : www.ekdantlab.co.in

TEST REPORT

Sample Ref No. : EES/W/160/06				Report No. : 1022/06		
Issued To : M/S. Birla Open Minds International School, SF No.498/12, Thulasi Garden, Chelliamman Kovil, main road, Athipet village, Chennai – 600 058.				Report Date : 30.06.2023 Page: 1 of 2		
Sample Description : Water				Received On : 28.06.2023		
Sample Drawn By/ Date : Customer / 28.06.2023				Commenced On : 28.06.2023		
Customer's Reference : Letter Dated On 28.06.2023				Completed On : 30.06.2023		
Sample Mark : RO water						
Sl. No	PARAMETERS	UNITS	RESULTS	As Per IS 10500:2012		PROTOCOL: APHA 23 rd Edition 2017
				Requirement (Acceptable limit)	Permissible limit in the absence of alternate source	
Physical Properties						
1	Appearance: When Analyzed After Filtration	-	Clear Clear	- -	- -	-
2	pH value at 25°C	-	6.54	6.5 – 8.5	6.5 – 8.5	4500 H ⁺ B
3	Color	Hazen	1.0	5	15	2120 B
4	Odor	-	Agreeable	Agreeable	Agreeable	IS 3025 P.5 1983
5	Turbidity	NTU	BLQ (LOQ=0.1)	1	5	2130 B
6	Electrical conductivity at 25°C	Micromhos/cm	138	-	-	2510 B
Chemical Properties						
7	Total Suspended Solids	mg/l	BLQ (LOQ=1.0)	-	-	IS:3025: P.17:1984
8	Total Dissolved Solids	mg/l	83.0	500	2000	IS 3025:P.16:1984

---End of Page1---



Elumalai m
Authorized Signatory

- NOTE: 1. Test results shown in this test report relate only to the items tested.
2. This test report shall not be reproduce anywhere except in full and in same format without the Approval of the laboratory
3. Unless informed by the customer the test items will not be retained for more than 10 days from The date of issue of test report (exceptional for Microbiology and wastewater for which retaining time 7 days.)

**TEST REPORT – ADDITIONAL SHEET**

Sample Ref No. : EES/W/160/06

Report No. : 1022/06
Report Date : 30.06.2023
Page: 2 of 2

Sl. No	PARAMETERS	UNITS	RESULTS	As Per IS 10500:2012		PROTOCOL: APHA 23 rd Edition 2017
				Requirement (Acceptable limit)	Permissible limit in the absence of alternate source	
9	Total Hardness as CaCO ₃	mg/l	31.0	200	600	2340 C
10	Calcium Hardness as CaCO ₃	mg/l	18.0	-	-	3500 - Ca B
11	Magnesium Hardness as CaCO ₃	mg/l	13.0	-	-	3500 - Mg B
12	Calcium as Ca	mg/l	7.0	75	200	3500 - Ca B
13	Magnesium as Mg	mg/l	3.0	30	100	3500 - Mg B
14	Phenolphthalein Alkalinity as CaCO ₃	mg/l	Nil	-	-	2320 B
15	Total Alkalinity as CaCO ₃	mg/l	22.0	200	600	2320 B
16	Chlorides as Cl	mg/l	13.0	250	1000	4500 Cl B
17	Sulfates as SO ₄	mg/l	1.0	200	400	4500 SO ₄ ²⁻ E
18	Total Iron as Fe	mg/l	BLQ (LOQ=0.01)	0.3	0.3	3500 Fe- B
19	Silica (Reactive) as SiO ₂	mg/l	2.0	-	-	IS 3025: P.35:1988
20	Carbonate Hardness as CaCO ₃	mg/l	22.0	-	-	2340 A
21	Non-Carbonate Hardness as CaCO ₃	mg/l	9.0	-	-	2340 A
22	Free Residual Chlorine	mg/l	BLQ (LOQ=0.1)	0.2	**1	4500 Cl B

BLQ= Below Limit of Quantification; LOQ= Limit of Quantification

** To be applicable only when water is chlorinated.

Remarks: The above submitted water sample comply with acceptable limits of drinking water specification as per IS 10500:2012 with respect to the above tests.

Ref. Decision Rule: EES/QSP/012

---End of Report---


Authorized Signatory

- NOTE:
1. Test results shown in this test report relate only to the items tested.
 2. This test report shall not be reproduce anywhere except in full and in same format without the Approval of the laboratory
 3. Unless informed by the customer the test items will not be retained for more than 10 days from The date of issue of test report (exceptional for Microbiology and wastewater for which retaining time 7 days.)



EKDANT ENVIRO SERVICES (P) LIMITED

NABL Accredited & MoEF Recognised Laboratory
An ISO 9001 : 2015 and OHSAS (ISO 45001 : 2018) Certified Company

No. R7/1, AVK Tower, North Main Road, Anna Nagar West Extn. Chennai - 600 101.
Phone : 044 - 2615 3349. Mobile : 94444 11178 / 94449 71649
E-mail : ekdantlab@gmail.com / ekdantfinance19@gmail.com
Web : www.ekdantlab.co.in

TEST REPORT

Sample Ref No. : EES/W/160/06	Report No. : 1022/06
Issued To : M/S. Birla Open Minds International School SF No.49812,Thulasi garden, Chelliamman kovil main road Athipet village Chennai 600058.	Report Date : 30.06.2023 Page: 1 of 1
Sample Description : Water Sample Drawn By/ Date : customer / 28.06.2023 Customer's Reference : Letter Dated On 28.06.2023 Sample Mark : RO water	Received On : 28.06.2023 Commenced On : 28.06.2023 Completed On : 30.06.2023

Sl.No	PARAMETERS	UNITS	RESULTS	Requirement as per IS 10500: 2012 Second revision (Acceptable Limit)	PROTOCOL
MICROBIOLOGICAL EXAMINATION					
1	Total Coliforms	100ml	Absent	shall not be detectable in any 100ml	IS:15185:2016
2	E.coli	100ml	Absent	shall not be detectable in any 100ml	IS:15185:2016

Report Opinion: The above submitted water sample complies with Acceptable limits of drinking water specification as per IS 10500:2012 with respect to the parameters tested above.

Ref. Decision Rule: EES/QSP/012

---End of Report---



Authorized Signatory

- NOTE:
1. Test results shown in this test report relate only to the items tested.
 2. This test report shall not be reproduce anywhere except in full and in same format without the Approval of the laboratory
 3. Unless informed by the customer the test items will not be retained for more than 10 days from The date of issue of test report (exceptional for Microbiology and wastewater for which retaining time 7 days.)